




Food Testing



Metallurgical Testing



Instruments Calibration



Environment Testing




Water Testing



Building Material Testing



Soil, Mineral & Agro Testing




Plastic, Rubber & Wooden Testing

Test Report

COOH

Report no. : Ch - L218138 to L218140 Date: 13/12/2021
 Name of Party : Jasper Polypast,
 Indor.
 Name of Sample : FRP Manhole Cover
 Grade/Variety/type/size/class : Nil
 Declared value, if any &
 Other Detail : Nil
 Sample id : Nil
 Quantity : 1 Piece
 Mode of Packing : Paper Box
 Sealed or not : Unsealed
 Any other information : Nil
 Date of receipt of sample : 13/12/2021
 Date of completion of testing : 13/12/2021

Industrial Testing



TEST RESULT ARE AS UNDER

Sr. No.	Sample No.	Size	Elements	Observe value
01	L218138	12x12	Breaking Load	32.62 kN
02	L218139	18x18	Breaking Load	28.32 kN
03	L218140	24x24	Breaking Load	31.04 kN

Remarks:

Prepared By



Reviewed & Authorized Signatory

(Hareesh Kaneriya)

NOTE:

(1) Sample not drawn by Yor Lab. (2) The Results relate only to the sample tested. (3) Yor lab has made their best endeavors to provide accurate and reliable information Yor Lab is not responsible for any financial liability due to any act of omission or error made. (4) Tested Samples are returned to Customer / preserved for 7 days. (5) Any ambiguity in test results should be brought forward to the lab management within this period. (6) Sample Related Information provided by Customer. (7) No Liability Accept if Sample Return Back. (8) The Test Report /Certificate Shall not be reproduced, except in full, without written permission of the laboratory.

-----END OF REPORT-----